

**STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT**



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 27-51-1593087 Name of Facility: Nature Coast Technical High School Address: 4057 California Street City, Zip: Brooksville 34604  Type: Public School Owner: Challenger K-8 School Person In Charge: R. Kretzer      Phone: 352-797-7088	<b>Correct By: Next Inspection</b> <b>Re-Inspection Date: None</b>
---	---

**Inspection Information**

Purpose: Routine Inspection Date: 9/20/2016	Begin Time: 10:00 AM End Time: 11:15 AM
--	--

**Additional Information**

FEMALES ..... 664 MALES ..... 674	CENSUS ..... 1338
--------------------------------------	-------------------

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

**Violation Markings**

SCHOOL SANITATION 1. School Site 2. Playground Equipment 3. Athletic Equipment BUILDINGS 4. Construction 5. Maintenance & Repair X 6. Lighting/Foot-Candles 7. Heating, Ventilation, A/C 8. Natural Ventilation 9. Mechanical Ventilation SANITARY FACILITIES 10. Provided/Accessible	11. Cleanliness & Repair 12. Toilet Facilities 13. Separation of Sexes 14. Fixture Ratio 15. Handwash Facilities 16. Showers/Fixtures 17. Shower Water Temp. WATER SUPPLY 18. Installed/Operated/Maintained 19. Drinking Fountains 20. Approved Source LIQUID/SOLID WASTE 21. Sewage Disposal	22. Solid Waste VECTOR/VERMIN CONTROL 23. Infestation/Control 24. Brush/Trash 25. Water Collection/Drainage SAFETY 26. First Aid Kit FOOD 27. Food Insp. Rpt. OTHER 28. 29.
---	---	--

**General Comments**

No General Comments Available  Email Address(es): kretzer_r@hcsb.k12.fl.us
--

Inspector Signature:

*Stef: [Signature]*

Client Signature:

*Pam Price*

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

Violation #6. Lighting/Foot-Candles  
Some lights out  
CODE REFERENCE: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.

Inspection Conducted By: Stefica Depovic (49765)  
Inspector Contact Number: Work: (352) 540-6800 ex. 82158  
Print Client Name: HCSB  
Date: 9/20/2016

Inspector Signature:

Handwritten signature of Stefica Depovic.

Client Signature:

Handwritten signature of Pam Price.