



**WEIGHT ROOM FLOORING**

**DOCUMENT NUMBER: 09700**

**APPLICATION: MIDDLE AND HIGH SCHOOL**

**DATE OF ISSUE: 10-31-2023**

**NOTES:**

Provide interlocking rubber flooring for weight rooms, meeting the following requirements:

Flooring to be equal to Kraiburg Sportec, 3'x3' mats.

Flooring to be compressed rubber with a pebbled, non - skid surface.

Flooring to have a fluted or waffled bottom to prevent the floor from creeping.

Flooring to be 3/4" thick and be provided with cushioned non-slip transition strips at all doors.